



Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Rc.No. 179 / SHP / DM&HO / Medchal / 2026 - 27.

Dated: 27 / 06 / 2026.

It is certified that an inspection team headed by Y. Vijay Kumar, Health Inspector, Medchal Malkajgiri District, from DM&HO Office (Health Department) and AR Clean Enviro Labs, Sai Nagar, Peerjadiguda, Medipally, Hyderabad certified PHED Lab have inspected M/s St. Anne's School, Located at Beside SBI Bank, Near Vegetable Market, Kushaiguda, Medchal - Malkajgiri District on 27-06-2026 and on the basis of Water Test Report (Attached) bearing No. CEL/W/02347/06/26-002, dated: 24-06-2026 from AR Clean Enviro Labs, Sai Nagar, Peerjadiguda, Medipally, Hyderabad (PHED Lab) certified that the St. Anne's School has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This Certificate is valid for a period of One year from date of issue.

[Signature]
Dist. Medical & Health officer
Medchal District

Signature with Seal:

Name: Dr. C. Uma Gowri., MBBS., MD

Designation: District Medical Health officer,

Name & Address of the Office: O/o DM&HO,

Medchal Malkajgir

To

The Principal,
St. Anne's School,
Beside SBI Bank,
Near Vegetable Market,
Kushaiguda,
MedchalMalkajgiri District.



AR CLEAN ENVIRO LABS

Water, Food & Environment Testing Laboratory
Recognized by MOEF & CC | Certified by ISO 9001:2015

8-85/1/F5, 1st floor, Plot No. 10 & 25
Sainagar, Peerzadiguda, Medipally,
Medchal Malkajgiri (Dist.),
Hyderabad-500098, Telangana, India
Ph : +91 8121165649 | 8801676472
E-mail : cleanenvirolabs@gmail.com
www.arcleanenvirolabs.com



TEST REPORT

TEST REPORT		
<u>Name and Address of the Client:</u> M/S. St. Anne's School Beside SBI Bank, Near Vegetable Market, Kushaiguda, Hyderabad, Telangana-500062.	ULR No	: TC1466026000003692F
	Sample Registration	: 02347/06/26-001
	Test Report No	: CEL/W/02347/06/26-001
	Report Issued Date:	: 24.06.2026
	Work Order Reference	: Nil
	Date of Receipt	: 19.06.2026
Group	: Water	
Discipline	: Chemical & Biological	
Sample Description	: RO Water	
Sample Quantity	: 1 Liter	
Sample Packing	: Plastic Bottle & Sterile Container	
	Date of Registration	19.06.2026
	Date of Commencement of Testing	19.06.2026
	Date of Completion of Testing	24.06.2026
	Sample Condition of Receipt	Found Ok
Sampling Details		
Date of Sampling : 19.06.2026		Environment Condition: Temperature :27.5° C, Humidity : 69.7%
Sampling Method: APHA 24 th Edition-1060-B(2023)		Sample Location: From Site.
Sample Collected By: CEL Representative (Hemanth)		

TEST RESULT

S. No	TEST PARAMETERS	TEST METHOD	UNITS	RESULTS	Acceptable Limits (As Per IS: 10500:2012)
1.	pH@25.0°C	APHA 24th Edition 4500 H+ B(2023)	--	6.76	6.5 - 8.5
2.	Electrical Conductivity	APHA 24th Edition 2510-B(2023)	µs/cm	42	Not Specified
3.	Total Dissolved Solids	APHA 24th Edition 2540-C(2023)	mg/l	16	Max. 500
4.	Turbidity	APHA 24th Edition 2130-B(2023)	NTU	< 1.0	Max.1.0
5.	Color	APHA 24th Edition 2120-C(2023)	CU	< 5.0	Max.5.0
6.	Total Alkalinity as CaCO ₃	APHA 24th Edition 2320-B(2023)	mg/l	< 10	Max. 200
7.	Total Hardness as CaCO ₃	APHA 24th Edition 2340-C(2023)	mg/l	< 10	Max. 200
8.	Calcium as Ca	APHA 24th Edition 3500 Ca-B(2023)	mg/l	< 10	Max. 75
9.	Magnesium as Mg	APHA 24th Edition 3500 Mg-B(2023)	mg/l	< 5.0	Max. 30
10.	Chlorides as Cl	APHA 24th Edition 4500 Cl-B(2023)	mg/l	< 10	Max. 250
11.	Sodium as Na	IS 3025 (Part 45):2024	mg/l	4.0	Not Specified
12.	Potassium as K	IS 3025 (Part 45):2024	mg/l	< 1.0	Not Specified
13.	Sulphates as SO ₄	APHA 24th Edition 4500 SO ₄ -2 E(2023)	mg/l	< 5.0	Max. 200
14.	Iron as Fe	APHA 24th Edition 3500 Fe B(2023)	mg/l	< 0.5	Max. 1.0
15.	Fluoride as F	APHA 24th Edition 4500 F- D(2023)	mg/l	< 0.2	Max. 1.0
16.	Silica as SiO ₂	APHA 24th Edition 4500 SiO ₂ C(2023)	mg/l	< 0.1	Not Specified
17.	Phosphorous	APHA 24th Edition 4500 P-C (2023)	mg/l	< 1.0	Not Specified
18.	Nitrates as NO ₃	APHA 24 th Edition - 4500 NO ₃ -C(2023)	mg/l	< 1.0	Max. 45
BIOLOGICAL PARAMETERS					
19.	Total Bacterial Count	IS 1622:1981	Cfu/ml	04	Not Specified
20.	Coliforms	IS 15185:2016	Per 100ml	Absent	Absent/100ml
21.	Escherichia coli	IS 15185:2016	Per 100ml	Absent	Absent/100ml

IS - Indian Standard, APHA - American Public Health Association, CFU - Colony Forming Units.

Remarks: The given water sample is suitable for drinking purpose as per the specifications given by IS 10500:2012

Verified By

T. Jyothirmai
(Sr. Chemist)

Authorized By

P. Sahadevudu
(Sr. Microbiologist)



*****END OF THE REPORT*****

F/7.8/03

Issue No & Date: 03&01.09.2024

Amend No. 03&01.09.2024

AR CLEAN ENVIRO LABS LLP

ISO 14001:2015

ISO 45001:2018

MSME



AR CLEAN ENVIRO LABS

Water, Food & Environment Testing Laboratory

Recognized by MOEF & CC | Certified by ISO 9001:2015

8-85/1/F5, 1st floor, Plot No. 10 & 25
Sainagar, Peerzadiguda, Medipally,
Medchal Malkajgiri (Dist.),
Hyderabad-500098, Telangana, India
Ph : +91 8121165649 | 8801676472
E-mail : cleanenvirolabs@gmail.com
www.arcleanenvirolabs.com



TC- 14660

TEST REPORT

Name and Address of the Client:

M/S. St. Anne's School

Beside SBI Bank, Near Vegetable Market,
Kushaiguda, Hyderabad, Telangana-500062.

ULR No : TC1466026000003693F
Sample Registration : 02347/06/26-002
Test Report No : CEL/W/02347/06/26-002
Report Issued Date: 24.06.2026
Work Order Reference : Nil
Date of Receipt : 19.06.2026

Group : Water
Discipline : Chemical & Biological
Sample Description : Bore Water
Sample Quantity : 1 Liter
Sample Packing : Plastic Bottle & Sterile Container

Date of Registration : 19.06.2026
Date of Commencement of Testing : 19.06.2026
Date of Completion of Testing : 24.06.2026
Sample Condition of Receipt : Found Ok

Sampling Details

Date of Sampling : 19.06.2026

Sampling Method: APHA 24th Edition-1060-B(2023)

Environment Condition: Temperature :27.5° C, Humidity : 69.7%

Sample Location: From Site.

Sample Collected By: CEL Representative (Hemanth)

TEST RESULT

S. No	TEST PARAMETERS	TEST METHOD	UNITS	RESULTS	Acceptable Limits (As Per IS: 10500:2012)
1.	pH@25.0°C	APHA 24th Edition 4500 H+ B(2023)	--	6.58	6.5 - 8.5
2.	Electrical Conductivity	APHA 24th Edition 2510-B(2023)	µs/cm	1825	Not Specified
3.	Total Dissolved Solids	APHA 24th Edition 2540-C(2023)	mg/l	864	Max. 500
4.	Turbidity	APHA 24th Edition 2130-B(2023)	NTU	< 1.0	Max.1.0
5.	Color	APHA 24th Edition 2120-C(2023)	CU	< 5.0	Max.5.0
6.	Total Alkalinity as CaCO ₃	APHA 24th Edition 2320-B(2023)	mg/l	292	Max. 200
7.	Total Hardness as CaCO ₃	APHA 24th Edition 2340-C(2023)	mg/l	328	Max. 200
8.	Calcium as Ca	APHA 24th Edition 3500 Ca-B(2023)	mg/l	73.6	Max. 75
9.	Magnesium as Mg	APHA 24th Edition 3500 Mg-B(2023)	mg/l	35.0	Max. 30
10.	Chlorides as Cl	APHA 24th Edition 4500 Cl-B(2023)	mg/l	248	Max. 250
11.	Sodium as Na	IS 3025 (Part 45):2024	mg/l	132	Not Specified
12.	Potassium as K	IS 3025 (Part 45):2024	mg/l	12	Not Specified
13.	Sulphates as SO ₄	APHA 24th Edition 4500 SO4-2 E(2023)	mg/l	68.2	Max. 200
14.	Iron as Fe	APHA 24th Edition 3500 Fe B(2023)	mg/l	0.10	Max. 1.0
15.	Fluoride as F	APHA 24th Edition 4500 F- D(2023)	mg/l	0.74	Max. 1.0
16.	Silica as SiO ₂	APHA 24th Edition 4500 SiO2 C(2023)	mg/l	0.24	Not Specified
17.	Phosphorous	APHA 24th Edition 4500 P-C (2023)	mg/l	< 1.0	Not Specified
18.	Nitrates as NO ₃	APHA 24 th Edition - 4500 NO ₃ -C(2023)	mg/l	24.6	Max. 45
BIOLOGICAL PARAMETERS					
19.	Standard Plate Count	IS 1622:1981	Cfu/ml	141	Not Specified
20.	Coliforms	IS 1622:1981	MPN/100ml	<2	Absent/100ml
21.	Escherichia coli	IS 1622:1981	MPN/100ml	<2	Absent/100ml

IS - Indian Standard, APHA - American Public Health Association, CFU - Colony Forming Units.

Note: <2 Indicates the minimum detection limit in the given sample & it is considered as absent.

Remarks: The given water sample is not suitable for drinking purpose as per the specifications given by IS 10500:2012

Verified By

T. Jyothirmai
(Sr.Chemist)

Authorized By

P. Sahadevudu
(Sr. Microbiologist)



*****END OF THE REPORT*****

F/7.8/03

Issue No & Date: 03&01.09.2024

Amend No. & Date: 00 & 00

AR CLEAN ENVIRO LABS LLP

ISO 14001:2015

ISO 45001:2018

MSME